



CORRIGENDUM-1
RFQ No.: AGL/47/INDORE/COCO/Interior Works/01-2024

Query

Sr.no.	Clause No./Document No.	Query Description	AGL Reply/Remarks
1	RFQ Document and SOR	Particle Board Specifications and make	<p>The particle board mentioned in all quantities is of High density IS: 3087 marked, with one side decorative and other side balancing lamination Grade I, Type II exterior grade IS: 12823 marked.</p> <p>Particle board makes:</p> <ol style="list-style-type: none">1. Century Prowud2. Archidply Decor Ltd.3. Associate Decor Ltd.4. Greenland Particle Boards Pvt Ltd.5. Shirdi Industries Ltd. (ASIS India)6. Action tesa
2	SOR. SR. NO. 5	<p style="text-align: center;">SIDE TABLE(S1) @ 1500LX600DX750HT</p> <p>TOP: - To be made up of 50mm thick MDF in white PU painted Finish</p> <p>UNDERSTRUCTURE: - MS under structure with Laser cut Leg in Sliver Grey Powder Coated finish</p>	<p>The top of table should be prelaminated with PVC edge band on all exposed edges instead of PU paint finish. Also, the under structure should be made of MS box pipes of 3 inches square section.</p>
3	SOR	WIRE MANAGEMENT	<p>The wire management is to be done in all work stations. This includes supply & installation of wire. It also includes supply and installation of Modular base & cover plate 6 module/ 8 module as per required. The Wire and Plate should be of reputed make.</p>

This Corrigendum-1 forms an integral part of the RFQ Document and a copy (duly signed and stamped) of the same is to be submitted along with the Bid.