

CORRIGENDUM - 3

E-TENDER NO.: AGL/Head Office/Contract and Purchase/20/25-26/ET/20 [CNG EMD COMPRESSORS] Dated 21.01.2026

Sl. No.	AGL Clause Description			Bidder's Query	AGL Reply	
1	SECTION I	16 of 124	8	SPECIAL CONDITIONS OF CONTRACT FOR ANNUAL RATE CONTRACT: Bidder has to quote lump-sum yearly Comprehensive AMC charges for each compressor for the next 04 years after Expiry of 1st Year Warranty period. Comprehensive AMC charges for each compressor for each of the next 04 years should not be less than: 1st Year Minimum AMC charges after Warranty Period : 10 % of compressor basic cost 2nd Year Minimum AMC charges after Warranty Period : 11 % of Compressor basic cost 3rd Year Minimum AMC charges after Warranty Period : 12 % of Compressor basic cost 4th Year Minimum AMC charges after Warranty Period : 13 % of Compressor basic cost	Please consider capping percentage based on the total of Basic cost of compressor + Freight + 1st year CAMC + String Test + Special Tools & Tackles + Re-transportation to Site/Store + Air compressor cost. Means based on the total of Sr. no. 1 to Sr. no. 5 from the SOR.	Tender Condition Prevails
2	SECTION I	16 of 124	2	Loading during bid evaluation: For Energy Consumption: $F = (G-Q) \times H \times Nop \times N$ Where, F = Loading amount in Rs. G = Guaranteed Energy consumption in Kwh for every 873 Kg (1200SCMH) of CNG Compressed for bidder under evaluation. Q = Lowest Guaranteed Energy Consumption Kwh for every 873 Kg (1200SCMH) of CNG Compressed (amongst technically accepted bidder)	To ensure fairness and prevent manipulation of consumption figures, we recommend incorporating the following capping criteria: "Energy Consumption should be in the range of 140 to 143 KWH for guaranteed parameters, no benefit will be given below 140 KWH."	Tender Condition Prevails
3	SECTION IX	16 of 124	11 to 15	SCHEDULE OF RATES (SOR) : 11 Operation 1st Year per Man-days per Compressor* (365 Days x 3 shifts) 1095 12 Operation 2nd Year per Man-days per Compressor* (365 Days x 3 shifts) 1095 13 Operation 3rd Year per Man-days per Compressor* (365 Days x 3 shifts) 1095 14 Operation 4th Year per Man-days per Compressor* (365 Days x 3 shifts) 1095 15 Operation 5th Year per Man-days per Compressor* (365 Days x 3 shifts) 1095	For the operation charges, we request that a minimum percentage of the total supply price be specified. This will help restrict bidders from quoting disproportionate values for supply and O&M. Total supply price = Basic cost of compressor + Freight + 1st year CAMC + String Test + Special Tools & Tackles + Re-transportation to Site/Store + Air compressor cost. (Total of Sr. no. 1 to Sr. no. 5 from the SOR).	Tender Condition Prevails
4	4.6	33 of 95	e)	IR Gas detectors General monitors/ Crow con /Honeywell/Sieger / Detronics/ Khrome Schroder / Net safety/ESP Safety Pvt.Ltd / M/s Oldham	Please accept Pollution Protection System Mumbai Pvt. Ltd.	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails
5	4.6	33 of 95	e)	UV flame detectors General monitors/ Crow con /Honeywell/Sieger / Detronics/ Khrome Schroder / Net safety/ESP Safety Pvt.Ltd / M/s Oldham	Please accept Pollution Protection System Mumbai Pvt. Ltd.	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails
6	4.6	33 of 95	g)	Mass flow meter Micromotion CNG 50, E&H	Please accept Emerson	Emerson and Micromotion is the same.
7	4.6	33 of 95	g)	Pressure Gauges & Temperatures Gauges M/s AN Instruments Pvt. Ltd., New Delhi/ M/s General Instruments Ltd., Mumbai/ M/s WIKA/ WAREE/ BAUMER / M/s Altop	Please accept Thermal Instrument, Gauge Bourdon	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails
8	4.6	33 of 95	k)	SS Tube Fittings/ On Off valve/non – return valve for CNG application M/s Swagelok (USA) / M/s Parker (USA)/ SSP/HOKE/HAMLET	Please accept Hylock, Astec, Fluid Control, Dawsons	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails
9	4.6	33 of 95	n)	SS Tube Fittings/ On Off valve/non – return valve for CNG application M/s Swagelok (USA) / M/s Parker (USA)/ SSP/HOKE/HAMLET	For High pressure we will supply as per the final tender approved vendor list but for low pressure fittings we will supply as per KPCL approved list vendors i.e. Tubefit, Astec, Seal Excel & Tubes-GMT.	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails
10	4.6	33 of 95	q)	Cables and wires INCAB/ Universal / ASEAN/CCI/FORT Closter/ Finolex/KEI, Associated cables Pvt Ltd./Polycab	Please accept Emerson Thermocable, Suyog Cable	PI refer clause 4 section 4.6 preferred makes. Tender condition prevails

This Corrigendum-3 forms an integral part of this e-Tender and a copy of the same is to be submitted along with the Bid.